



Annexure C

PRO FORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.AEE/RDW&SD/SAUNDATTI/2025-26/ 225

Dated:25.07.2025

It is certified that an inspection team headed by Giresh D Chavan AE (Name of Officers with designation) from R.D.W & S D inspected the **SHRI SHIVAYOGEEESHWAR ENGLISH MEDIUM SCHOOL, INCHAL, SAUNDATTI, BELAGAVI, KARNATAKA** (Name & Address of the school) on 25.07.2025 (date of inspection) and on the basis of Water Test Report bearing no.10 &11dated 11.07.2025 of Sub Divisional Water Quality (R.D.W&SD) (PHED Lab) certified that the **SHRI SHIVAYOGEEESHWAR ENGLISH MEDIUM SCHOOL, INCHAL,** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. The School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till :24.07.2026

Assistant Ex Engineer

R.D.W & S.D Sub Division Saundatti

Signature with Seal

Name: B. V. Aiyanagoud

Designation: Assistant Executive Engineer

Name & Address of the Office/Department :

R.D.W & S.D Sub Division Saundatti



To

**SHRI SHIVAYOGEEESHWAR ENGLISH
MEDIUM SCHOOL, INCHAL
SAUNDATTI, BELAGAVI,
KARNATAKA**

Note:The certificate is to be issued by authorized officer/PHEDLab/local bodies



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Sub Divisional Water Quality Chemical Testing Laboratory
Near Shivaji Circle, PWD Compound Saundatti-591126
E-mail:rdwsd.wqmosp.saundatti@gmail.com

TEST REPORT					
Address of the sampling location: Taluk: Saundatti Location of Source: Shri Shivayogeeswar English Medium School Inchal.				Report date: 11-07-2025	
				Report Number:0011	
				Reference: Sample receipt Form	
				Sample receipt date: 09-07-2025	
				Sample code: SOU25JULPRI0011	
				Date of Sample collection: 09-07-2025	
				Analysis start date: 10-07-2025	
				Analysis completion date: 10-07-2025	
Sample Particulars: Drinking Water (Filter)				Sample collection protocol: APHA Method	
				Sample quantity: 1 Litre	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1.	pH Value @Temp 25.0°C	6.52	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, $\mu\text{S}/\text{cm}$ @Temp 25.0°C	42	–	–	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
5.	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
7.	Total Dissolved Solids@ 180°C, mg/l	24	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as CaCO_3 , mg/l	3.90	200	600	IS 3025 (Part-23) : 2023
9.	Total Hardness as CaCO_3 , mg/l	8.08	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	1.61	75	200	IS 3025 (Part-40) : 2024
11.	Magnesium as Mg, mg/l	0.98	30	100	IS 3025 (Part-46) : 2023
12.	Chloride as Cl, mg/l	1.92	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO_4 , mg/l	1.31	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.18	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO_3 , mg/l	4.15	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	0.00	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks: The given sample conforms to the Acceptable limit of IS: 10500:2012 RA 2018 drinking water specifications for above tested physical and chemical parameters only					
Analysed by:  Analyst			Verified By:  Assistant Executive Engineer		

RDWSD/WQMSP/TeR/01

Note:



- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

End Of Report

P.B. Swamiji
ADMINISTRATIVE OFFICER
Shri Shivanand Bharati Education Society,
INCHAL-591102.
Tq: Saundatti. Dist: Belagavi



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Sub Divisional Water Quality Chemical Testing Laboratory
Near Shivaji Circle, PWD Compound Saundatti-591126
E-mail:rdwsd.wqmosp.saundatti@gmail.com

TEST REPORT					
Address of the sampling location: Taluk: Saundatti Location of Source: Shri Shivayogeeswar English Medium School Inchal.				Report date: 11-07-2025	
				Report Number:0010	
				Reference: Sample receipt Form	
				Sample receipt date: 09-07-2025	
				Sample code: SOU25JULPRI0010	
				Date of Sample collection: 09-07-2025	
				Analysis start date: 10-07-2025	
				Analysis completion date: 10-07-2025	
Sample Particulars: Borewell Water				Sample collection protocol: APHA Method	
				Sample quantity: 1 Litre	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1.	pH Value @Temp 25.0°C	7.09	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, $\mu\text{S}/\text{cm}$ @Temp 25.0°C	1092	-	-	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	-	Agreeable	Agreeable	IS 3025 (Part-8):2023
5.	Colour, Hazen Units	5	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	0.8	1	5	IS 3025 (Part-10) : 2023
7.	Total Dissolved Solids@ 180°C, mg/l	624	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as CaCO_3 , mg/l	206.70	200	600	IS 3025 (Part-23) : 2023
9.	Total Hardness as CaCO_3 , mg/l	299.22	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	66.37	75	200	IS 3025 (Part-40) : 2024
11.	Magnesium as Mg, mg/l	32.39	30	100	IS 3025 (Part-46) : 2023
12.	Chloride as Cl, mg/l	119.56	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO_4 , mg/l	41.57	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.65	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO_3 , mg/l	44.86	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	0.05	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks: The given sample conforms to the Permissible limit of IS: 10500:2012 RA 2018 drinking water specifications for above tested physical and chemical parameters only					
Analysed by: 			Verified By:  Assistant Executive Engineer		

RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

End Of Report

P. B. Swamiji
ADMINISTRATIVE OFFICER
Shri Shivanand Bharati Education Society,
INCHAL-591102.
Tq: Savadatti. Dist: Belagavi